

Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impctg@pupin.rs

SERTIFIKAT

☒ O PREGLEDU TIPa / Type examination

Broj / Number: T 2332

☐ POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: ITALTHERM S.p.A. Via S. D'Acquisto, 10, 29010
Pontenure, Italija / Italy

preduzeto je/
has been undertaken: Kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj /
Number: T 2332

sa dokumentima u prilogu /
with attached documents: - Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju KIWA broj 2001134/9; / Test
reports KIWA No 2001134/9

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: GASNI KOTAO /
GAS BOILER

proizveden od /
manufactured by: ITALTHERM S.p.A. Via S. D'Acquisto, 10, 29010
Pontenure, Italija / Italy

oznaka - tip - serija /
mark - type - series:

ITALTHERM CITY CLASS H...K
ROMSTAL EcoHeat 500, H ... K
vrsta/type: B₂₃, B_{23P}, B₅₃, B_{53P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu
i ocenjivanje usaglašenosti gasnih aparata ("Sl.
gl. RS", br. 41/2015)
SRPS EN 15502-2-1:2017

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.
Ocenjivanje sprovedeno / Evaluation performed from 16.10.2023. - 29.12.2023.

izdat od / issued by:

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE


Kristina Petković dipl.maš.inž.

mesto, datum / place, date

Beograd, 29.12.2023.



Ime, Prezime / Name, Surname



Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

Prilog A / Annex A

Broj / Number: T 2332

Strana / Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

ITALTHERM CITY CLASS H... K
ROMSTAL EcoHeat 500, H... K

vrsta/type: B₂₃, B_{23P}, B₅₃, B_{53P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃
kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
ITALTHERM CITY CLASS H...K ROMSTAL EcoHeat 500, H... K		
... 25 K	$Q_n=2,6 \div 21,0$ (25*) kW $P_n=2,4 \div 20,3$ kW	za grejanje i pripremu tople sanitarne vode (TSV) sa ugrađenim pločastim izmenjivačem/ for heating and preparation of domestic hot water (DHW) with built-in plate heat exchanger
... 30 K	$Q_n=2,6 \div 25,0$ (30*) kW $P_n=2,4 \div 24,3$ kW	
... 35 K	$Q_n=3,5 \div 28,0$ (33,2) kW $P_n=3,2 \div 26,3$ kW	
... 25 KR	$Q_n=2,6 \div 21,0$ (25*) kW $P_n=2,4 \div 20,3$ kW	- za grejanje i povezivanje na spoljni bojler za TSV/ for heating and connecting to an external drinking water storage for DHW
... 35 KR	$Q_n=3,5 \div 28,0$ (33,2) kW $P_n=3,2 \div 26,3$ kW	

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one
year within the assessment of the Declaration of Conformity with the type!